

**Goochland County Fire EMS
Dry Fire Hydrant
Test Maintenance Report**

Dry Hydrant Serial No.	Station	Dry Fire Hydrant Address/Location	GPS Coordinates		Maintenance / Repair										
					Steamer (in)	Adaptor (in)	Date Tested	Flow (GPM)	Condition	Head	Support Bracket	Strainer	See Attachment		
075001		Summerchase Ln	37° 44.009N	077° 52.690W	6	4.5	Jul-09	1830	OK						
075002		1556 Broad Street Rd.	37° 42.477N	077° 47.646W	6	4.5	Jul-09	N/A	No Water					X	
075003		28 Junie Buck Dr	37° 41.645N	077° 40.656W	4.5		Jul-09	N/A	N/A						
075004		1434 Hockett Rd.	37° 39.458N	077° 40.737W	6	4.5	Jul-09	1880	OK						
075005		12850 Broad St	37° 40.183N	077° 40.303W	6	4.5	Jul-09	1810	OK						
075006		Hermitage Rd.	37° 36.749N	077° 43.410W	4.5		Jul-09	1390	OK						
075007		Perrow Ln., Broad Run IV	37° 38.012N	077° 42.203W	6	4.5	Jul-09	1780	OK						
075008		Marry Go Round Rd.	37° 37.484N	077° 44.812W	6	4.5	Jul-09	1830	OK						
075009		Old Logan Rd.	N/A	N/A			Jul-09		Removed						
075010		Behind 11 Broad Run Rd. on golf cart-path	37° 38.715N	077° 42.367W	6	4.5	Jul-09	1490	OK						
075011		Fed Ln	37° 41.177N	077° 42.956W	4.5		Jul-09	1390	OK						
075012		1520 Manakin Rd.	37° 39.702N	077° 29.223W	4.5		Jul-09	1020	OK					X	
075013		Virginia Farm Bureau (West Creek Business Park)	37° 36.675N	077° 38.931W	4.5		Jul-09	1270	OK						
075014		4673 Three Square Rd.	37° 40.270N	078° 00.671W	6	4.5	Jul-09	1840	OK						
075015		2390 Whitehall Acres	37° 43.315N	077° 51.360W	6	4.5	Jul-09	1790	OK						
075016		1125 Manakin Rd.	37° 38.096N	077° 42.823W	6	4.5	Jul-09	1670	OK						
075017		375 Running Cedar Trail	37° 37.019N	077° 42.820W	6	4.5	Jul-09	1580	OK						
075018		1551 Carriage Dr.	N/A	N/A	6	4.5	Jul-09	N/A	Removed						
075019		1768 Fox Downs Ln.	37° 41.351N	077° 46.145W	4.5		Jul-09	1480	OK					X	
075020		Royal Ridge Ct	37° 51.268N	078° 01.290W	4.5		Jul-09	1880	OK						
075021		2428 Hampden Row	37° 42.356N	077° 42.247W	6	4.5	Jul-09	1880	OK						
075022		604 Nelwood Cove	37° 42.152N	077° 43.130W	4.5		Jul-09	1770	OK						
075023		1700 Alvis Rd.	37° 40.697N	077° 43.881W	6	4.5	Jul-09	1790	OK						
075024		595 Three Chopt Rd.	37° 40.363N	077° 43.077W	4.5		Jul-09	1500	OK					X	
075025		12696 Pamela Ln.	37° 40.021N	077° 39.760W	6	4.5	Jul-09	1530	OK						
075026		Sneed Rd.	37° 37.253N	077° 41.632W	6	4.5	Jul-09	1900	OK						
075027		5930 Old Columbia Rd.	37° 46.078N	078° 06.660W	4.5		Jul-09	1870	OK						
075028		2620 Danielstown Rd.	37° 44.921N	078° 01.701W	6	4.5	Jul-09	1940	OK						

Silver Creek INC
16083 Coatesville Road
Beaverdam, VA 23015
804/852-7426

**Goochland County Fire EMS
Dry Fire Hydrant
Test Maintenance Report**

Dry Hydrant Serial No.	Station	Dry Fire Hydrant Address/Location	GPS Coordinates		Maintenance / Repair									
					Steamer (In)	Adaptor (In)	Date Tested	Flow (GPM)	Condition	Head	Support Bracket	Strainer	See Attachment	
075029		1950 Haskins Rd. (616) 3/4 mile w Rt. 600	37° 42.215N	078° 01.148W	6		Jul-09	1850	OK					
075030		910 Three Chopt Rd.	37° 41.720N	077° 44.743W	4.5		Jul-09	1320	OK					
075031		Yellow Gate Rd.	37° 38.164N	077° 45.466W	4.5		Jul-09	980	OK				X	
075032		Dover Rd.	37° 37.661N	077° 45.828W	4.5		Jul-09	1330	OK					
075033		Broadland Way	37° 45.438N	077° 54.123W	4.5		Jul-09	1300	OK					
075034		2212 Camelback Rd.	37° 42.712N	077° 50.376W	6		Jul-09	1970	OK					
075035		Cedar Plains Rd.	37° 47.165N	077° 57.599W	4.5	2.5	Jul-09	1300	OK					
075036		2721 Sandy Hook Ln (Koolwaters)	37° 44.796N	077° 54.120W	4.5		Jul-09	1050	OK					
075037		801 Rockcastle Rd.	37° 38.014N	077° 58.022W	6		Jul-09	1390	OK					
075038		Bolling Hall Farm Dr	37° 41.015N	077° 57.775W	6		Jul-09	1200	OK					
075039		4356 Broad Street Rd.	37° 48.903N	077° 57.333W	6	4.5	Jul-09	1990	OK					
075040		Hadensville Farm Ln.	37° 50.055N	077° 57.858W	4.5	2.5	Jul-09	1850	OK					
075041		Broad Street Rd.(250)			4.5	2.5								
075042		1680 Old Orchard Ln.	37° 40.118N	077° 43.147W	6	4.5	Jul-09	1400	OK					
075043		Hermitage County Club @ Clubhouse	37° 38.769N	077° 42.264W	6	4.5	Jul-09	1500	OK					
075044		Tabscott Rd. (603)	37° 49.260N	078° 03.147W	6	4.5	Jul-09	1850	OK					
075045		Windsor Lake Dr. @ Lake	37° 52.133N	078° 00.954W	4.5	2.5	Jul-09	1580	OK					
075046		next to 1551 Windsor Way (712) (Auburn Chase Sub.)	37° 38.309N	077° 43.841W	6	4.5	Jul-09	1880	OK					
075047		1564 Oak Grove Dr.	37° 39.975N	077° 41.021W	4.5		Jul-09	1540	OK					
075048		2285 River Rd. West (private install on swimming pool)			6	4.5	Jul-09							
075049		1920 Soldiers Lodge Rd. (private drive)												
075050		Jackson Shop Rd. (607N) 0.3 mile from Route 6	37° 42.158N	077°55.117W	6	4.5	Jul-09	1680	OK					
075051		Woodson Place (Lot 10), Meadow Subdivision	37° 37.169N	077° 44.654W	6	4.5	Jul-09	N/A				X		
075052		2152 Mankin Rd. (621 N)	37° 40.666N	077° 42.038W	6	4.5	Jul-09	1900	OK					
075053		4610 Broad Street Road (250) across frm 4633 drive	37° 50.105N	077° 59.137W	6	4.5	Jul-09	1660	OK					
075054		2855 Poorhouse Rd. (633)	37° 43.285N	077° 52.354W	6	4.5	Jul-09	1880	OK				X	
075055		4669 Shannon Hill Rd. (605)	37° 51.127N	078° 04.673W	6	4.5	Jul-09	1650	OK				X	
075056		4605 Hickory Hill Rd. (609)	37° 49.603N	078° 02.668W	6	4.5	Jul-09	1780	OK					

Silver Creek INC
16083 Coatesville Road
Beaverdam, VA 23015
804/852-7426

**Goochland County Fire EMS
Dry Fire Hydrant
Test Maintenance Report**

Dry Hydrant Serial No.	Station	Dry Fire Hydrant Address/Location	GPS Coordinates		Maintenance / Repair										
					Steamer (in)	Adaptor (in)	Date Tested	Flow (GPM)	Condition	Head	Support Bracket	Strainer	See Attachment		
075057		Hermitage Rd. (676) Hermitage County Club	37° 38.430N	077° 42.008W	6	4.5	Jul-09	1570	OK						
075058		The Preserve Drive - The Preserve at Deerfield Subdivision	37° 42.376N	077° 48.738W	6	4.5	Jul-09	1500	OK						
075059		The Forest Road (private) The Forest Subdivision	37° 39.061N	077° 48.517W	6	4.5	Jul-09	1900	OK						
075060		1580 Millers Ln. (644)	37° 39.412N	077° 43.593W	6	4.5	Jul-09	1540	OK						
075061		2596 Elk Island Rd. (603)	37° 44.952N	078° 06.784W	6	4.5	Jul-09	1630	OK						
075062		1094 Stokes Station Rd. (616)	37°39.314N	078° 02.663W	6	4.5	Jul-09	1800	OK						
075063		2210 Denver Ln.	37° 40.001N	077° 51.201W	6	4.5	Jul-09	1610	OK						
075064		1699 Maidens Rd. (634) Robert E. Lee Boy Scout Camp	37° 40.526N	077° 51.787W	6	4.5	Jul-09	1710	OK						
075065		646 Seay Rd. (626)	37° 42.160N	077° 43.275W	6	4.5	Jul-09	1840	OK						
075066		5722 Mayo Lake Dr	37° 47.693N	078° 04.389W	6	4.5	Jul-09	1900	OK					X	
075067		1245 Flat Rock Crossing (Sabot Hill)	37° 38.485N	077° 45.032W	6	4.5	Jul-09	1970	OK						
075068		Pond off Pemberton on the James	37° 67.092N	078° 07.183W	6	4.5	Jul-09	1730	OK						
075069		5380 Community House Road	37° 78.493N	078° 05.724W	6	4.5	Jul-09	1880	OK						
075070		2020 Fair Grounds Road	37° 70.100N	077° 82.771W	4.5		Jul-09	1300	OK						
075071		2671 Broad Street Rd. (250)	37° 75.412N	077° 86.973W	6	4.5	Jul-09	1470	OK						
075072		End of Crest Hollow Ct.	37° 70.601N	077° 90.563W	4.5		Jul-09	1170	OK						
075073		End of Incline Ct.	37° 70.480N	077° 90.528W	4.5		Jul-09	1410	OK						

COMMENTS ATTACHMENT

075002 Standpipe loose, needs soil packed back around base. Pond level to low to get draft

075012 Homeowner has wood piled up in front of hydrant requiring 2 sections of hardsleeve to hook-up. 4" system

075019 Poor Access - site needs All Weather Access.

075024 Needs All Weather Access

075031 Due to limited flow it is recommend that consideration be given to replacing system at some time in future

075051 Head needs to be replaced

075054 Lowered standpipe

075055 Needs All Weather Access

075066 Needs All Weather Access (rock)